

MAA AMBE TOTAL SOLUTION

Authorise Franchise : Refture Management Pvt. Ltd.

Authorised Dealer : Kent, Jaquaro RO Plant

GRD. FLOOR, OM CHAMBER, NR. HOTEL UDIPI, STATION ROAD, NAVSARI-396 445. PH.: 02637-255558 / 93759 53000

Bio-Health



Shree Radhagovind Vidyamandir,
Ninat,

Date: 25/08/2025

Subject: Regarding drinking water Parameter in school and Hostel

Sir,

As per subject we have installed and doing service of RO plant in school and Hostel of Shree Radhagovind Vidyamandir on regular basis. The drinking water quality is hygienic and Parameter are given below.

- | | |
|------------------------|---------|
| (1) Raw water TDS | 550 PPM |
| (2) Finished water TDS | 59 PPM |
| (3) Finished water PH | 7.12 |

Thanks & Regards
MAA AMBE TOTAL SOLUTIONS

N. R. Desai

PROPRIETOR

Nailesh R Desai